

PROPOSED CHANGE

NBC05-DivB-03.02.05.19.(01)-replace-FP-A_V2_ed.doc

MODIFICATION PROPOSÉE

Page: 1 of / de 1

[Comment](#)

[Commentaires](#)

Document	NBC 2005	Document
Provision	A-3.2.5.19.(1)	Exigence
Committee	Fire Protection	Comité
Minutes	6.2.1. WG-Referenced Standards; 4.6.11. and 7.6.10.14. Standing Committee on FPProcès-verbaux	

EXISTING PROVISION

A-3.2.5.19.(1) Fire Pumps. In order to ensure an adequate water supply, it may be necessary to install a fire pump for a building that has either a standpipe system or an automatic sprinkler system installed. Reference to NFPA 20, "Installation of Stationary Pumps for Fire Protection," provides the necessary guidance to designers.

PROPOSED CHANGE

Replace Appendix Note A-3.2.5.19.(1) as follows:

Other Code Provisions Affected: None

A-3.2.5.19.(1) Fire Pumps. In order to ensure an adequate water supply, it may be necessary to install a fire pump for a building that has either a standpipe system or an automatic sprinkler system installed. ~~Reference to NFPA 20, "Installation of Stationary Pumps for Fire Protection," provides the necessary guidance to designers.~~

RATIONALE

Problem

The reference to NFPA 20 in the Appendix Note is redundant.

Justification - Explanation

Editorial. Clarification.

Cost implications

None.

Enforcement implications

None.

Who is affected

Architects, builders, owners, regulators.

OBJECTIVE-BASED ANALYSIS OF NEW OR CHANGED PROVISION

Provision: A-3.2.5.19.(1)

Analysis: N/A

Attributions

Objective

[Comment](#)

[Commentaires](#)